

Special Quality Assurance Documents (SQAD)



SQAD-6 Quality Control Notice (QCN)

Sub Code: LIM1

Requirements for Limitorque MOVA Parts and Motors

PROCUREMENT REQUIREMENTS:

- 1 Technical and Quality requirements are as defined in Exelon Nuclear Procurement Engineering Standard PES-P-010, current revision.
- 2 Vendor shall provide certification that a videoscope inspection has been performed for each safety related (Flowserve) Limitorque AC motors.