

SQAD-6 Quality Control Notice (QCN)

Sub Code: CLNR

Cleaning of Fluid Systems and Associated Components for Nuclear Power Plants

For Nuclear Safety Related fluid systems and components - each item for which this quality statement is specified shall be cleaned in accordance with ANSI N45.2.1 to the levels and classes specified in the Exelon PO/Contract and its references.

For Non-Nuclear Safety Related fluid systems and components - each item for which this quality statement is specified shall be cleaned in accordance with Manufacturer's standard cleaning practices and shall include removal of residual quantities of cutting fluids, liquid penetrants, weld fluxes, pre-cleaning solutions, engineering test fluids and other process compounds utilized.