

SQAD-6 Quality Control Notice (QCN)

Sub Code: RVFS

Regulatory Guide 1.65, Requirements for Reactor Vessel Fastener Strength

The following tensile and yield limitations shall be met:

1. In accordance with NRC Regulatory Guide (RG) 1.65, Revision 0, the measured ultimate tensile strength as documented in the CMTR shall not exceed 170 ksi.
2. In accordance with NRC Regulatory Guide (RG) 1.65, Revision 1, the measured yield strength as documented in the CMTR shall not exceed 150 ksi.